



# Certificate of Compliance

**Certificate:** 70218631

**Master Contract:** 259077

**Project:** 80135819

**Date Issued:** 2022-08-08

**Issued to:** Altenergy Power System Inc.  
No.1 Yatai Road  
Jiaxing, Zhejiang, 314050  
CHINA

**Attention:** Kevin Lu

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



**Issued by:** *Magic Zhang*  
Magic Zhang

## PRODUCTS

CLASS 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS 5311 89 - POWER SUPPLIES - Distributed Generation Power Systems Equipment - Certified to U.S. Standards

APsmart Rapid Shutdown System:

Model	Attenuators	Initiation Device	System Ratings
Type-A	RSD-S-PLC-A	Transmitter-PLC	System voltage 1000Vdc, Attenuators Input: 8~80Vdc, 15Amax per module, 15A max input short circuit. Attenuators Output: 8~80Vdc, 15Amax, 800W max per module. Rapid shutdown time limit 15s. Initiated by the loss of AC power
Type-B	RSD-S-PLC-B	Transmitter-PLC	System voltage 1500Vdc, Attenuators Input: 8~80Vdc, 15Amax per module, 15A max input short circuit. Attenuators Output: 8~80Vdc, 15Amax, 800W max per module. Rapid shutdown time limit 15s. Initiated by the loss of AC power



**Certificate:** 70218631

**Master Contract:** 259077

**Project:** 80135819

**Date Issued:** 2022-08-08

Type-C	RSD-S-PLC-A	Transmitter-PLC-PCBA	System voltage 1000Vdc, Attenuators Input: 8~80Vdc, 15Amax per module, 15A max input short circuit. Attenuators Output: 8~80Vdc, 15Amax, 800W max per module. Rapid shutdown time limit 15s. Initiated by the loss of AC power
Type-D	RSD-S-PLC-B	Transmitter-PLC-PCBA	System voltage 1500Vdc, Attenuators Input: 8~80Vdc, 15Amax per module, 15A max input short circuit. Attenuators Output: 8~80Vdc, 15Amax, 800W max per module. Rapid shutdown time limit 15s. Initiated by the loss of AC power

Model	Attenuators	Initiation Device	Inverter	System Ratings
APsmart's RSD system, PVRSS: Sunspec	Altenergy Power System Inc. RSD-S-PLC-A RSD-S-PLC-B RSD-D-15-1000 RSD-D-20-1000 RSD-D-25-1000 RSD-D-15-1500 RSD-D-20-1500 RSD-D-25-1500	Altenergy Power System Inc. Transmitter-PLC Transmitter-PLC-PCBA Transmitter-PLC-1P	SHANGHAI CHINT POWER SYSTEMS CO., LTD. CPS SCA60KTL-DO/US-480 CPS SCA50KTL-DO/US-480 CPS SCA25KTL-DO-R/US-480 CPS SCA20KTL-DO-R/US-480 CPS SCA25KTL-DO/US-208	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the loss of AC power.
	Zhejiang Twinsel Electronic Technology Co., Ltd. PV-SY020-A PV-SY020	Baoding Yitong PV Science&Technology Co., Ltd. Transmitter-PLC Transmitter-PLC-PCBA	Delta Electronics (Shanghai) Co., Ltd. M10-4-TL-US M10-TL-US M8-TL-US M6-TL-US M5-TL-US M4-TL-US E8-TL-US E6-TL-US E4-TL-US	600 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the loss of AC power.
	Baoding Yitong PV Science&Technology Co., Ltd. YT-RSD-P-1000 YT-RSD-P-1500		LG ELECTRONICS, INC. D007KEEN261	600 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

				Initiated by the loss of AC power.
			Solectria Renewables, LLC PVI 50TL-480 PVI 60TL-480 PVI 20TL-480-R PVI 25TL-480-R PVI 25TL-208	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.
			JIANGSU GOODWE POWER SUPPLY TECHNOLOGY CO., LTD. GW9600A-ES, GW8600A-ES, GW7600A-ES, GW7000A-ES, GW6000A-ES, GW5000A-ES, GW9600A-MS, GW8600A-MS, GW7600A-MS, GW7000A-MS, GW6000A-MS, GW5000A-MS, GW9600A-IS, GW8600A-IS, GW7600A-IS, GW7000A-IS, GW6000A-IS, GW5000A-IS GW9600H-ES, GW8600H-ES, GW7600H-ES, GW7000H-ES, GW6000H-ES, GW5000H-ES,	Initiated by the loss of AC power.  600 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the DC Switch on the inverter.

**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

			<p>Shenzhen Growatt New Energy Technology Co., Ltd          SPH 3000TL BL-US,          SPH 3600TL BL-US,          SPH 4000TL BL-US,          SPH 4600TL BL-US,          SPH 5000TL BL-US,          SPH 6000TL BL-US</p>	<p>550 Vdc maximum system voltage.</p> <p>Rapid shutdown time limit 30s with inverter.</p> <p>Initiated by external emergency button with signal wire connected to the Inverter's ELV circuit.</p>
			<p>Shenzhen Growatt New Energy Technology Co., Ltd          MIN 8200TL-XH-US,          MIN 9000TL-XH-US,          MIN 10000TL-XH-US,          MIN 11400TL-XH-US,          MIN 3000TL-XH-US,          MIN 3800TL-XH-US,          MIN 5000TL-XH-US,          MIN 6000TL-XH-US,          MIN 7600TL-XH-US</p>	<p>600 Vdc maximum system voltage.</p> <p>Rapid shutdown time limit 30s with inverter.</p> <p>Initiated by external emergency button with signal wire connected to the Inverter's ELV circuit.</p>
			<p>FIMER S.p.A.:</p> <p>1) UNO-DM-3.3-TL-PLUS-US-XYZ-ABC-DE-F,          2) UNO-DM-3.8-TL-PLUS-US-XYZ-ABC-DE-F,          3) UNO-DM-4.6-TL-PLUS-US-XYZ-ABC-DE-F,          4) UNO-DM-5.0-TL-PLUS-US-XYZ-ABC-DE-F.          (X: blank, S;</p>	<p>600 Vdc maximum system voltage.</p> <p>Rapid shutdown time limit 30s with inverter.</p> <p>Initiated by the loss of AC power.</p>



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

			<p>Y = blank, B, E, Z;  Z = blank, M;  A = blank, X;  B = blank, R;  C = blank, A;  D = blank, Q;  E = blank, U;  F = blank, AP, TI)</p>	
			<p>FIMER S.p.A.:  UNO-DM-6.0-TL-  PLUS-US-XYZ-ABC-  DE-F  (X: blank, S;  Y = blank, B, E, Z; Z  = blank, M;  A = blank, X;  B = blank, R;  C = blank, A;  D = blank, Q;  E = blank, U;  F = blank, AP, TI)</p>	<p>600 Vdc  maximum  system voltage.</p> <p>Rapid shutdown  time limit 30s  with inverter.</p> <p>Initiated by the  loss of AC  power</p>
			<p>Delta Electronics, Inc.  E10_BDI  E8_BDI  E6_BDI  E4_BDI  E10-TL-US  E8 Plus-TL-US  EC8-US  EC6-US  EC4-US</p>	<p>600 Vdc  maximum  system voltage.</p> <p>Rapid shutdown  time limit 30s  with inverter.</p> <p>Initiated by the  loss of AC  power</p>
			<p>Shenzhen  Eternalplanet Energy  Pingshan Ltd.:  HNA7W,  HNA7W_TT,  HNA7W_AT,  HNA7G,  HNA7G_TT,  HNA7G_AT</p>	<p>600 Vdc  maximum  system voltage.</p> <p>Rapid shutdown  time limit 30s  with inverter.</p> <p>Initiated by  external  emergency  button with  signal wire  connected to the</p>



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

				Inverter's ELV circuit.
APsmart's RSD system, PVRSS: Sunspec	Altenergy Power System Inc. RSD-S-PLC-A RSD-S-PLC-B RSD-D-15-1000 RSD-D-20-1000 RSD-D-15-1500 RSD-D-20-1500  Zhejiang Twinsel Electronic Technology Co., Ltd. PV-SY020-A PV-SY020  Baoding Yitong PV Science&Technology Co., Ltd. YT-RSD-P-1000 YT-RSD-P-1500	Altenergy Power System Inc. Transmitter-PLC Transmitter-PLC-PCBA Transmitter-PLC-1P	Ginlong Technologies Co., Ltd. Solis-75K-5G-US, Solis-80K-5G-US, Solis-90K-5G-US, Solis-100K-5G-US, S5-GC75K-US, S5-GC80K-US, S5-GC90K-US, S5-GC100K-US.	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the loss of inverter power of AC Grid.
		Baoding Yitong PV Science&Technology Co., Ltd. Transmitter-PLC Transmitter-PLC-PCBA	CSI Solar Co., Ltd. CSI-75K-T480GL02-U, CSI-80K-T480GL02-U, CSI-90K-T480GL02-U, CSI-100K-T480GL02-U.	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the loss of inverter power of AC Grid.
APsmart's RSD system, PVRSS: Sunspec	Altenergy Power System Inc.: RSD-S-PLC-A RSD-S-PLC-B RSD-D-15-1000 RSD-D-20-1000 RSD-D-25-1000 RSD-D-15-1500 RSD-D-20-1500 RSD-D-25-1500.	Altenergy Power System Inc.: Transmitter-PLC, Transmitter-PLC-1P	Jiangsu RCT Power Energy Technology Co., Ltd: Power Storage DC US-8.0	520 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the disconnecting external AC breaker in the field.



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

Model	Attenuators	Initiation Device	Inverter	System Ratings
APsmart's RSD system, PVRSS: Sunspec	Altenergy Power System Inc. RSD-S-PLC-A RSD-S-PLC-B RSD-D-15-1000 RSD-D-20-1000 RSD-D-25-1000 RSD-D-15-1500 RSD-D-20-1500 RSD-D-25-1500	Integrated in Fronius inverter as listed in the just right column of this table	Fronius International GmbH Fronius Symo Advanced 10.0-3 208-240 Fronius Symo Advanced 12.0-3 208-240	600 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the loss of AC power
	Zhejiang Twinsel Electronic Technology Co., Ltd. PV-SY020-A PV-SY020		Fronius International GmbH Fronius Symo Advanced 15.0-3 480 Fronius Symo Advanced 20.0-3 480 Fronius Symo Advanced 22.7-3 480 Fronius Symo Advanced 24.0-3 480	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter  Initiated by the loss of AC power
	Baoding Yitong PV Science&Technology Co., Ltd. YT-RSD-P-1000 YT-RSD-P-1500		Fronius International GmbH Primo GEN24 3.8 208-240 Primo GEN24 5.0 208-240 Primo GEN24 6.0 208-240	600 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by external buttons with signal wire connected to the WSD interface of the Inverter.
		Integrated in Ginlong inverters as listed in the just right column of this table	Ginlong Technologies Co., Ltd. Solis-50K-US-SW; Solis-50K-US-LSW; Solis-66K-US-F-SW; Solis-66K-US-F-LSW; Solis-60K-US-F-SW; Solis-60K-US-F-LSW;	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

			<p>Solis-50K-US-F-SW;  Solis-50K-US-F-LSW;  Solis-40K-US-F-SW;  Solis-40K-US-LSW;  Solis-40K-US-SW;  Solis-36K-US-SW;  Solis-36K-US-F-SW;  Solis-36K-US-LSW;  Solis-30K-US-F-SW;  Solis-30K-US-LSW;  Solis-30K-US-SW;  Solis-25K-US-SW;  Solis-25K-US-F-SW;  Solis-25K-US-LSW;</p>	<p>Initiated by the loss of AC power</p>
		<p>Integrated in Ginlong inverters as listed in the just right column of this table</p>	<p>Ginlong Technologies Co., Ltd.  Solis-1P10K-4G-US;  Solis-1P9K-4G-US;  Solis-1P8.6K-4G-US;  Solis-1P8K-4G-US;  Solis-1P7.6K-4G-US;  Solis-1P7K-4G-US;  Solis-1P6K-4G-US;  Solis-1P6K2-4G-US;  Solis-1P5K-4G-US;  Solis-1P4.6K-4G-US;  Solis-1P4K-4G-US;  Solis-1P3.6K-4G-US;  Solis-1P3K-4G-US;  Solis-1P2.5K-4G-US;  Solis-1P2K-4G-US;  Solis-1P1.5K-4G-US;  Solis-1P1K-4G-US;</p>	<p>600 Vdc maximum system voltage.   Rapid shutdown time limit 30s with inverter.   Initiated by the loss of inverter power of AC Grid.</p>
		<p>Integrated in Ginlong inverters as listed in the just right column of this table</p>	<p>Ginlong Technologies Co., Ltd.  RHI-1P5K-HVES-5G;  RHI-1P6K-HVES-5G;  RHI-1P7K-HVES-5G;  RHI-1P7.6K-HVES-5G;  RHI-1P8K-HVES-5G;  RHI-1P9K-HVES-5G;  RHI-1P10K-HVES-5G;</p>	<p>500 Vdc maximum system voltage.   Rapid shutdown time limit 30s with inverter.   Initiated by the loss of AC power</p>





**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

		Integrated in Candian Solar inverters as listed in the just right column of this table	Canadian Solar Inc. : CSI-66K-T480GL01-UB, CSI-60K-T480GL01-UB, CSI-50K-T480GL01-UB, CSI-40K-T480GL01-UB, CSI-36K-T480GL01-UB, CSI-30K-T480GL01-UB, CSI-25K-T480GL01-UB. CSI-25KTL-GS-FLB, CSI-30KTL-GS-FLB, CSI-36KTL-GS-FLB, CSI-40KTL-GS-FLB, CSI-40KTL-GS-B, CSI-50KTL-GS-FLB, CSI-50KTL-GS-B, CSI-60KTL-GS-B, CSI-66KTL-GS-B	1000 Vdc maximum system voltage.  Rapid shutdown time limit 30s with inverter.  Initiated by the loss of AC power
--	--	--	---	---

Model	Attenuators	Initiation Device	Inverter	System Ratings
APsmart Rapid Shutdown System, PVRSS: Sunspec	Altenergy Power System Inc. RSD-S-PLC-A RSD-S-PLC-B RSD-D-15-1000 RSD-D-20-1000 RSD-D-25-1000 RSD-D-15-1500 RSD-D-20-1500 RSD-D-25-1500  Zhejiang Twinsel Electronic Technology Co., Ltd. PV-SY020-A; PV-SY020;  Baoding Yitong PV Science & Technology Co., Ltd.	Altenergy Power System Inc. Transmitter-PLC	Manufacturer: SolaX Power Network Technology (Zhejiang) Co., Ltd.  Family series (1) Models: A1-Hybrid-6.0-US, A1-Hybrid-7.0-US, A1-Hybrid-7.6-US, A1-Hybrid-8.6-US;  Family series (2) Models: A1-6.0-US, A1-7.0-US, A1-7.6-US, A1-8.6-US	600 Vdc maximum system voltage.  Rapid shutdown time limit 30 s with inverter.  Family series (1) Initiated by external emergency button with signal wire connected to the Inverter's ELV circuit.  Family series (2) Initiated by



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

	YT-RSD-P-1000; YT-RSD-P-1500;		<p>Manufacturer: Hanhua Q CELLS America Inc.</p> <p>Family series (1):  Q.HOME<sup>+</sup> HYB-G1-X.X series, models:  Q.HOME<sup>+</sup> HYB-G1-6.0, Q.HOME<sup>+</sup> HYB-G1-7.0, Q.HOME<sup>+</sup> HYB-G1-7.6, Q.HOME<sup>+</sup> HYB-G1-8.6;</p> <p>Family series (2):  Q.HOME<sup>+</sup> AC-G1-X.X series, models:  Q.HOME<sup>+</sup> AC-G1-6.0, Q.HOME<sup>+</sup> AC-G1-7.0, Q.HOME<sup>+</sup> AC-G1-7.6, Q.HOME<sup>+</sup> AC-G1-8.6;</p>	<p>the loss of AC Grid.</p> <p>600 Vdc maximum system voltage.</p> <p>Rapid shutdown time limit 30 s with inverter.</p> <p>Family series (1) Initiated by external emergency button with signal wire connected to the Inverter's ELV circuit.</p> <p>Family series (2) Initiated by the loss of AC Grid.</p>
--	----------------------------------	--	---	--

**Note:**

1. For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.



**Certificate:** 70218631  
**Project:** 80135819

**Master Contract:** 259077  
**Date Issued:** 2022-08-08

**APPLICABLE REQUIREMENTS**

- UL Std. No. 1741-Third Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Third Edition, Dated September 28, 2021)
- CSA C22.2 No. 330-17 - Photovoltaic rapid shutdown systems

Note: Photovoltaic Rapid Shutdown Function has also been evaluated according to CEC Code, Part I, Rule 64-218; NEC-2017 and NEC-2020 Section 690.12 applicable requirement.

**Notes:**

Products certified under Class C531109 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)

