



Certificate of Compliance

Certificate: 70218632

Master Contract: 259077

Project: 80201203

Date Issued: 2024-03-05

Issued to: ALTENERGY POWER SYSTEM INC.
Building 2, No. 522, Yatai Road, Nanhu District
Jiaxing City, Zhejiang, 314050
CHINA

Attention: Kevin Lu

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only



Issued by: *Levi Sun*
Levi Sun

PRODUCTS

CLASS 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS 5311 89 - POWER SUPPLIES - Distributed Generation Power Systems Equipment - Certified to U.S. Standards

Photovoltaic Rapid Shutdown System Equipment, Model No. RSD-S-PLC-A and RSD-S-PLC-B, used to cut off the DC connection of PV modules after the Transmitter power supply circuit breaker is off. Rack mounted or mounted to the PV module with adhesive. PLC communication used.

Initiation device, Model No. Transmitter-PLC, contain three installation models: 1) Transmitter-PLC-PCBA, 2) Transmitter-PLC, 3) Transmitter-PLC-1P.

Note:

1. For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.
2. Photovoltaic Rapid Shutdown Function has also been evaluated according to NEC-2017/NEC-2020/NEC-2023 Section 690.12 applicable requirement and CEC-2018, CEC-2021 Sec 64-218 applicable requirement.



Certificate: 70218632
Project: 80201203

Master Contract: 259077
Date Issued: 2024-03-05

APPLICABLE REQUIREMENTS

- UL Std. No. 1741-Third Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Third Edition, Dated May 19, 2023)
- CSA C22.2 No. 330-23 - Photovoltaic rapid shutdown systems

Note:

1. CSA C22.2 No. 330-23 is used in conjunction with CSA C22.2 No.107.1-16 - General Use Power Supplies.
2. Compliance with UL 1741- Third Edition (Dated May 19, 2023) include compliance with applicable requirement of UL 991, Edition 3, Tests for Safety-related controls employing solid-state devices.
3. Compliance with CSA C22.2 No. 330-23 include compliance with applicable requirement of CSA C22.2 No. 0.8 -12 Safety functions incorporating electronic technology.

Notes:

Products certified under Class C531109 have been certified under CSA’s ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

