



# Certificate of Compliance

**Certificate:** 80054217

**Master Contract:** 259077

**Project:** 80214053

**Date Issued:** 2024-06-11

**Issued to:** ALTENERGY POWER SYSTEM INC.  
Building 2, No. 522, Yatai Road, Nanhu District  
Jiaxing City, Zhejiang, 314050  
CHINA

**Attention:** Kevin Lu

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only*



**Issued by:** *Magic Zhang*  
Magic Zhang

## PRODUCTS

CLASS 5311 09 - POWER SUPPLIES - Distributed Generation Power Systems Equipment

CLASS 5311 89 - POWER SUPPLIES - Distributed Generation Power Systems Equipment - Certified to U.S. Standards

Photovoltaic Rapid Shutdown System Equipment, Models No. RSD-D-15-1000, RSD-D-20-1000, RSD-D-25-1000, RSD-D-15-1500, RSD-D-20-1500 and RSD-D-25-1500, used to cut off the DC connection of PV modules after the PLC signal lost. Rack mounted. PLC communication used.

### Note:

1. For details related to rating, size, configuration, etc., reference should be made to the CSA Certification Record, Certificate of Compliance Annex A, or the Descriptive Report.
2. Photovoltaic Rapid Shutdown Function has also been evaluated according to NEC-2017/NEC-2020/NEC-2023 Section 690.12 applicable requirement and CEC-2018/CEC-2021 Sec 64-218 applicable requirement.



**Certificate:** 80054217  
**Project:** 80214053

**Master Contract:** 259077  
**Date Issued:** 2024-06-11

### **APPLICABLE REQUIREMENTS**

UL Std. No. 1741-Third Edition - Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources (Third Edition, Dated May 19, 2023)  
CSA C22.2 No. 330-23 - Photovoltaic rapid shutdown systems

Note:

1. CSA C22.2 No. 330-23 is used in conjunction with CSA C22.2 No.107.1-16 - General Use Power Supplies.
2. Compliance with UL1741-Third Edition (Dated May 19, 2023) include compliance with applicable requirement of UL 991, Edition 3, Tests for Safety-related controls employing solid-state devices.
3. Compliance with CSA C22.2 No. 330-23 include compliance with applicable requirement of CSA C22.2 No. 0.8 -12 Safety functions incorporating electronic technology.

Notes:

Products certified under Class C531109 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). [www.scc.ca](http://www.scc.ca)

